



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Product	prestressing steel
Type	strand-prEN 10138-3-Y1860S7-12,5-1-R1-F2-C1
Intended use	for the prestressing of concrete
Performances	see annex 1
Manufacturer	PRIVATE JOINT STOCK COMPANY "STALKANAT", 16, Vodoprovidna Str. Odesa, 65007, Ukraine
Manufacturing plant	PRIVATE JOINT STOCK COMPANY "STALKANAT", 52A, Vapnyana Str. Odesa, 65006, Ukraine
Requirements	EprEN 10138-1:2009, EprEN 10138-3:2009 and declared by the producer performances (see annex 1)

This certificate is issued having performed actions prescribed for system 1+ in STR 1.01.04:2015 and confirms that the product complies with requirements set out in this certificate.

Number	SPSC-9573
Date of issue	2025-01-03 (first issued on 2019-05-03)
Valid until	2028-01-03 (information www.spsc.lt)
Granted to	PRIVATE JOINT STOCK COMPANY "STALKANAT", 16, Vodoprovidna Str. Odesa, 65007, Ukraine, company code EDRPOU 44437592

Director



Valdemaras Gauronskis

Copy No. 1 EN

ANNEX 1 TO CERTIFICATE No. SPSC-9573

Issued 2025-01-03

Product prestressing steel
Type strand-prEN 10138-3-Y1860S7-12,5-I-R1-F2-C1

Essential characteristics and performances

Essential characteristic	Test method	Performance
Tensile strength, MPa	LST EN ISO 15630-3:2019	1860
Characteristic value of maximum force F_m , kN	LST EN ISO 15630-3:2019	173
Characteristic value of 0,1 % proof force $F_{p0,1}$, kN	LST EN ISO 15630-3:2019	152
Elongation at maximum force A_{gt} , %	LST EN ISO 15630-3:2019	$\geq 3,5$
Relaxation at 1000 h, for initial force corresponding to 70 % F_{ma} , % and class	LST EN ISO 15630-3:2019	$\leq 2,5$ R1
Diameter d , mm (nominal value)	LST EN ISO 15630-3:2019	12,5
Cross-sectional area S_n , mm ² (nominal value)	LST EN ISO 15630-3:2019	93,0
Mass per metre, g/m	LST EN ISO 15630-3:2019	$726,3 \pm 2 \%$
Surface geometry	LST EN ISO 15630-3:2019	indented, pass
Fatigue, number of stress cycles and class	LST EN ISO 15630-3:2019	2×10^6 F2
Modulus of elasticity E , GPa (design value)	FprEN 10138-3:2009	195
Deflected tensile strength, D-value, %	LST EN ISO 15630-3:2019	≤ 28
Durability, class	LST EN ISO 15630-3:2019	C1

Director




Valdemaras Gauronskis